

				TEST RESULTS			
Contaminant	Date	Violatio Y/N	Level Detected	Unit Measurement	MCL	MCL	Likely Source of Contamination
1. Alpha emitters							
		N	4.1-25.2	pCi/L	0	15	Erosion of natural deposits
	10/30/03	Y		pCi/L	0	15	
Inorganic Contaminant							
Barium							
	9/20/07	N	.71-.232	ppm	2	2	Discharge of drilling wastes, refineries, erosion of natural deposits
Arsenic							
	6/07-10/02/07	N	2-9	ppb	10	10	Erosion of natural desopits
	8/08/08	N	7	ppb	10	10	Erosion of natural desopits
10. Copper							
	9/13/07	N	.163 90th %	ppm	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives
12. Fluoride							
	9/20/07	N	.5-1	ppm	4	4	Erosion of natural deposits, water additive which provides for stronger teeth, discharge from fertilizer and aluminum factories
13. Lead							
	12/31/07	N	7 90th %	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
16. Nitrate (as Nitrogen)							
	4/30-11/20/08	N	ND-9.6	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion, of natural deposits
18. Selenium							
	9/20/07	N	1-8	ppb	50	50	Discharge from petroleum and metal refineries, erosion discharge from mines
Chromium							
	9/20/07	N	1-3	ppb	100	100	Discharge from steel and pupl mills. Errosion of natural deposits
Eythlene Dibromide (EDB)							
	8/12/08	N	ND	ppy	50	50	Discharge from petroleum refineries
Total Coliform							
	1/03-12/18/08	N	A	ppm	0	0	Naturally present in the environment

I am pleased to present to you our first Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water currently pumped from six _____ wells. Our wells darw from _____